

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490021	ARROW POINT WATER CO	C	84	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: WARREN

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		2 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30				
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 5/31/25		Complete		
	10/1/25 - 12/31/25				
Total Coliform (3100)		3 repeat (RP) per period			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	5/6/25 - 5/11/25		Complete		
	6/24/25 - 6/29/25		Complete		
Total Coliform (3100)		3 temporary routine (TR) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30			
	1/1/27 - 12/31/29	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: **ENTRY POINT - WELL #1 (WSF ID: 00700)**

Net Gross Alpha (4000)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL #1 POE (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
Uranium (4006)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL #1 POE (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
Combined Radium-226/228 (4010)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL #1 POE (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490021	ARROW POINT WATER CO	C	84	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: WARREN

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL #1 (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 POE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 POE (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 POE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 POE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Water System Facility: ENTRY POINT - WELL #2 (WSF ID: 00701)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 POE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 POE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 POE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 POE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 POE (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490021	ARROW POINT WATER CO	C	84	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: WARREN

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL #2 (WSF ID: 00701)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) **1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL #2 POE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) **1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL #2 POE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Water System Facility: WELL 2 (WSF ID: 994)

E. Coli (3014) **1 triggered (TG) per period**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 2 (2)	5/5/25 - 5/11/25		Complete
	6/23/25 - 6/29/25		Complete

Water System Facility: WELL 1 (WSF ID: 996)

E. Coli (3014) **1 triggered (TG) per period**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)	5/5/25 - 5/11/25		Complete
	6/23/25 - 6/29/25		Complete

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CERTIFY LEAD SL NOTIFICATION	7/1/2025	
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION EXEMPTION	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		ARROWPT001	#25 ARROW POINT RD	A	Y	1	Y	
		ARROWPT002	#26 ARROW POINT RD	A		1	Y	
		ARROWPT003	#33 ARROW POINT RD	A		1	Y	
		ARROWPT004	#44 ARROW POINT RD	A		1	Y	
		ARROWPT005	#13 ARROW POINT RD	A		1	Y	
		ARROWPT006	#11 ARROW POINT RD	A	Y	1		
		ARROWPT007	#14 ARROW POINT RD	A	Y	1		
		ARROWPT008	#27 ARROW POINT RD	A	Y	1		
		ARROWPT009	#31 ARROW POINT RD	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490021	ARROW POINT WATER CO	C	84	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		24					

Towns Served: WARREN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		ARROWPT010	#15 ARROW POINT RD	A	Y	1		
		ARROWPT011	#46 ARROW POINT RD	A	Y	1		
		ARROWPT012	#34 ARROW POINT RD	A	Y	1		
		ARROWPT013	#37 ARROW POINT RD	A	Y	1		
		ARROWPT014	#41 ARROW POINT RD	A	Y	1		
		ARROWPT015	#38 ARROW POINT RD	A	Y	1	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - WELL #1	3	WELL #1 POE	A				
00701	ENTRY POINT - WELL #2	3	WELL #2 POE	A				
37733	WELL 1 HYDROPNEUMATIC TANK							
37735	WELL 2 HYDROPNEUMATIC TANK							
994	WELL 2	2	WELL 2	A				
996	WELL 1	2	WELL 1	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
KILBOURN, ERIC M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025
KILBOURN, JORDAN H	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027

Contact Information

Name			Organization			Job Title		
Arrow Point Water Co								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
Emergency Contact						Emergency Contact	CT	06000
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-868-9995								
Contact Role(s): Owner								
Name			Organization			Job Title		
Mr. Richard Rebusmen			Arrow Point Water Co.			Director		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
P.O. Box 2363			26 Arrow Point Road			New Preston	CT	06777
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-868-6750				860-868-6750	richardr44@sbcglobal.net			
Contact Role(s): Administrative Contact, Legal Contact, Owner								

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490021	ARROW POINT WATER CO	C	84	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		24					

Towns Served: WARREN

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule